

Certificate of Compliance

Certificate Number:

R41092

Report Reference:

R41092-20240530

Issue Date:

2024-06-10

Issued to:

**EFS Engineering Ltd.
393 Harishonim St
Ein Vered 40696 Israel**

This certificate confirms that representative samples of:

FIRE-PROTECTIVE CURTAINS

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

**UL 10D, Fire Tests of Fire Protective Curtain Assemblies
UL 1784, Air Leakage Tests of Door Assemblies and Other
Opening Protectives
NFPA 105, Smoke Door Assemblies and Other Opening
Protectives**

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number R41092
Report reference R41092-20240530
Date 2024-06-10

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

EFS-FC, Single Barrel, Fire-Protective Curtains, surface or between-jamb mounted, rated up to and including 2 hr., for use in masonry wall type constructions for openings not exceeding 6000 mm (236.22 in) in width and 4200 mm (165.35 in) in height, also rated for air leakage assemblies for openings not exceeding 3048mm (120 in.) in height and 3048 mm (120 in.) in width.



David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

